




राष्ट्रीय इस्पात निगम लिमिटेड

(भारत सरकार का उपक्रम)

Rashtriya Ispat Nigam Limited

(A Government of India Undertaking)



18-01-2017

To,

Pegasus Engineering & Commercial Corporation

Visakhapatnam

SUB : Performance Report for NCIWC Anti Scale Instrument (Pegasus Make)

Dear Sir,

With reference to your request letter PECC/F9/335 dated 17-01-2017 we confirm that the (NCIWC) Anti scale instrument was installed at our facility on 29-08-2016 at ASU 4 BAC OIL COOLER and TURBINE SYSTEM for approximately 4 months.

We confirm that during our shutdown on 05-01-2017 we found that there was NO SCALE formation and no blockage in our BAC oil cooler tubes.

Hence we state that the performance of the above said instrument (NCIWC) found to be satisfactory and good solution for scaling issues in various applications.

This is for your information as you needed through your request letter.

Thanking you.

Manoranjan Mandal

18/01/17

(Agm) Utilities Department

RINL

Visakhapatnam

हिन्दी के प्रयोग का स्वागत है, पत्र का उत्तर शघ्रि दिया जायेगा ।

Please send your reply to :

Phones : +91 891 -

Fax : +91 891 -

E-mail :

website : www.vizagsteel.com

**VIZAG**  
**STEEL**  
RASHTRIYA ISPAT NIGAM LIMITED

**PRIDE**  
**of STEEL**

विशाखपट्टणम इस्पात संयंत्र, विशाखपट्टणम - 530 031

Visakhapatnam Steel Plant, Visakhapatnam - 530 031

Regd. Office : Visakhapatnam Steel Project, Administrative Building, Visakhapatnam - 530 031, INDIA.

पंजीकृत कार्यालय : विशाखपट्टणम इस्पात परियोजना, प्रशासनिक भवन, विशाखपट्टणम - 530 031, भारत.